

EirGrid Ex-Ante Outturn Available Connection Asset Maintenance Plan for the 2022 Outage Season

[Transmission Outage Programme 2022](#)

Introduction

The Single Electricity Market Committee (SEMC) decision SEM-15-071 “Process for the Calculation of Outturn Availability”, published on 29 September 2015, required that the TSOs establish a forum which will be responsible for publication of separate ex-ante outage plans for Northern Ireland and Ireland. The SEMC decision also required that the ex-ante outage plans for each outage season be sent to the RAs for review. This Ex-Ante Outturn Available Connection Asset (OACA) Annual Maintenance Plan contains the scheduled maintenance of Outturn Availability Connection Assets for the 2022 outage season as scheduled and issued to individual Generators.

The Ireland Ex-Ante Outturn Availability Forum takes place in Q1 annually. At this forum, the format and content of the Ex-Ante OACA Annual Maintenance Plan is presented for discussion. This report is also sent to the RAs in draft for review prior to publication on the EirGrid website.

This Ex-Ante OACA Annual Maintenance Plan forms the baseline for the 2022 outage season against which changes will be reported. The Ex-Ante OACA Annual Maintenance Plan includes details of the individual work items, the scheduling status, scheduled dates or planned window, the maintenance duration associated with the work and a unique identifier (Transmission Outage Programme identifier also known as a TOP-ID) for each OACA. Changes to generator outages, maintenance duration or scope, the planned window, scheduled dates and designated days are being tracked and these, along with work completed will be reported ex-post at the Ex-Post Forum in Q1 2023 and in the EirGrid Ex-Post Outturn Availability Connection Asset Maintenance Report for the 2022 Outage Season.

Note: Transmission Outage Programme Timelines

The Transmission Outage planning process aims to increase flexibility in the outage programme to the benefit of our customers by better accommodating project changes as they occur with the least disruption. In doing so it is anticipated that the amount of work which can be carried out on the transmission system in a given outage season will be maximised with a nominal amount of schedule changes. A full programme of work for the year ahead was developed in February, in which work items were classified as Planned or Scheduled. Outages several months in the future are initially classified as Planned. As the outage window approaches, the outage will move to a scheduled state.

Outage Classification	Outage Description
<i>Planned</i>	A viable outage window identified to complete a particular work item. Works will not be assigned a date until later in the outage season, for example works which are not expected to take place until several months in the future. These works are given an indicative outage window (date range) in which a fixed duration of work will be carried out.
<i>Proposed</i>	An outage slot for the work to be completed in, with proposed specific start and end dates. This is an intermediary stage between <i>Planned</i> and <i>Scheduled</i> where dates have been proposed by the TSO but not yet confirmed by all parties.
<i>Scheduled</i>	Outages scheduled with specified start and end dates, where these dates are unlikely to change. The outage dates are scheduled approximately 4 weeks before the start of the relevant month.

Details of designated days for Outturn Availability purposes will be assigned when the outage is scheduled (i.e. when the outage moves to the scheduled state which will happen typically 4 weeks in advance of the relevant month).

The following section includes details of the maintenance works planned for OACAs for the 2022 outage season. The total maintenance duration is the actual length of time of the works, with works running concurrently this may not always be the sum of the durations of the individual work items.

2022 OACA Annual Maintenance

110kV FEEDER - AGANNYGAL DERRYBRIEN

TO-22-AGL-DYN-1-01

Window: **Jun**

Duration: **(3 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
	AGL	-	DO	3	4	OIL SAMPLING OF CT /R/S/T/ and INSPECT RUBBER BELLOWS
	DYN		DO	2	2	P2 Protection maintenance of 7SA513

220kV FEEDER - AGHADA LONG POINT

TO-22-AD-LPT-1-01

ISO week: **36mo - 36fr**

Date: **05 Sep - 09 Sep**

Duration: **5 Days (5 WD)**

Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	AD~	-	DO	5	4	220kV SF6 Cubicle Ordinary Service
CORRECT	LPT	901240106	DO	2	4	Repeat Oil Sampling

GENERATOR TRANSFORMER - AGHADA T2011/12

TO-22-AD-T2011/12-01

Window: **Jul**

Duration: **(2 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	DO	2	N/A	Total Maintenance Outage Duration Requested
AMCAB	AD~	-	DO	2	4	Annual Insp. 400 & 220 Station OF Cable
FO_CABLE	AD~	901247447	DO		4	2021PM_Monitor oil pressure levels withi

GENERATOR TRANSFORMER - AGHADA T2014

TO-22-AD-T2014-01

Window: **Jul - Aug**

Duration: **(12 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	1	P1 Protection maintenance of 7SA612, R1Z23b
N/A	-	-	DO	12	N/A	Total Maintenance Outage Duration Requested
OS	AD~	-	DO	5	4	220kV SF6 Cubicle Ordinary Service
CORRECT	AD~	901246243	DO	5	4	2021PM_Replace S-Phase differential rela
CA_220	AD~	-	DO	3	4	220KV CUBICLE CONDITION ASSESSMENT
AMCAB	AD~	-	DO	2	4	Annual Insp. 400 & 220 Station OF Cable
CORRECT	AD~	901222071	DO	2	4	O1-T2014 CB Leaking Air
FO_CABLE	AD~	901167032	DO	1	4	Clean CSE stand-off insulators in Aghada

GENERATOR TRANSFORMER - ARDNACRUSHA GIS T101

TO-22-AA GIS-T101-01

ISO week: **17mo - 17fr**

Date: **25 Apr - 29 Apr**

Duration: **5 Days (5 WD)**

Status:

Scheduled

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612
N/A	-	-	DO	5	N/A	Total Maintenance Outage Duration Requested
OSGIS110	AA~	-	DO	4	4	110KV GIS Cubicle Ordinary Service

GENERATOR TRANSFORMER - ARDNACRUSHA GIS T102

TO-22-AA GIS-T102-01

Window: **Jun**

Duration: **(5 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OSGIS110	AA~	-	DO	4	4	110KV GIS Cubicle Ordinary Service
AICX4/2F	AA~	-	DO	2	4	Cable Insp. 110kV XLPE

GENERATOR TRANSFORMER - ARDNACRUSHA GIS T103

TO-22-AA GIS-T103-02

Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612

TO-22-AA GIS-T103-01

Window: **Sep**

Duration: **(2 WD)**

Status: **Planned**

N/A	-	-	N/A	DO	2	N/A	Total Maintenance Outage Duration Requested
AICX4/2F	AA~	-	DO	2	4		Cable Insp. 110kV XLPE

GENERATOR TRANSFORMER - ARDNACRUSHA GIS T104

TO-22-AA GIS-T104-01

ISO week: **14mo - 14fr**

Date: **04 Apr - 08 Apr**

Duration: **5 Days (5 WD)**

Status:

Scheduled

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OSGIS110	AA~	-	DO	4	4	110KV GIS Cubicle Ordinary Service
AICX4/2F	AA~	-	DO	2	4	Cable Insp. 110kV XLPE

COUPLER/SECTIONALISING CB - ATHEA 110SA1-2CB

TO-22-ATE-110SA1-2CB-01

Window: **May - Jun**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	2	N/A	Total Maintenance Outage Duration Requested
OPT	ATE		DO	1	4	110kV SF6 Cubicle Operational Test	
OPT	ATE	110-SA1	DO	1	4	110kV Sect / Dist Operational Test	
OPT	ATE	110-SA2	DO	1	4	110kV Sect / Dist Operational Test	

110kV FEEDER - ATHEA DROMADA

TO-22-ATE-DRO-1-01

Window: **May - Jun**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
FO_CABLE	-	-	901167020	DO	2	4	Clean CSE stand-off insulators in Dromad
N/A	-	-	N/A	DO	2	N/A	Total Maintenance Outage Duration Requested

110kV FEEDER - ATHEA KNOCKANURE

TO-22-ATE-KNR-1-01

Window: **May - Jun**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	KNR	-	DO	4	4	110kV SF6 Cubicle Ordinary Service	

GENERATOR TRANSFORMER - ATHEA T121

TO-22-ATE-T121-02

Window: **May - Jun**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
			DO	2	3	P3 Protection maintenance of 7SA612	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	ATE	110	DO	1	4	110kV SF6 Cubicle Operational Test	

110kV FEEDER - ATHEA TOBERTOREEN

TO-22-ATE-TOB-1-01

Window: **May - Jun**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	ATH		DO	1	4	110kV SF6 Cubicle Operational Test	

110kV FEEDER - AUGHINISH SEALROCK 3

TO-22-AUG-SK-3-02

Window: **Nov**

Duration: **(3 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
CA_110	AUG	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT

TO-22-AUG-SK-3-01

Window: **Jul**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	7	N/A	Total Maintenance Outage Duration Requested
OS	AUG	-	DO	4	4	110kV SF6 Cubicle Ordinary Service	

110kV FEEDER - AUGHINISH SEALROCK 4

TO-22-AUG-SK-4-02

Window: **Oct**

Duration: **(3 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
CA_110	AUG	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT

TO-22-AUG-SK-4-01

Window: **Jun**

Duration: **(3 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
OS	AUG	-	DO	4	4	110kV SF6 Cubicle Ordinary Service

110kV FEEDER - BALLYNAHULLA CORDAL

TO-22-BYH-CDL-1-02

 Window: **Sep**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AMCAB	-	-		DO	2	4	Cable Insp. 400 & 220kV Feeder XLPE
OS	BYH	-		DO	4	4	110kV GIS Cubicle Ordinary Service
OS	CDL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
	CDL			DO	2	3	P3 Protection maintenance of 7SA612, GRL100

110kV FEEDER - BALLYVOUSKILL COOMATAGGART

TO-22-BVK-COT-1-02

 Window: **Oct**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A		2	N/A	Total Maintenance Outage Duration Requested
OPT	BVK		DO	1	4	110kV SF6 Cubicle Operational Test	
OPT	COT		DO	1	4	110kV SF6 Cubicle Operational Test	

110kV FEEDER - BALLYWATER CRANE

TO-22-BWR-CRA-1-01

 Window: **Aug**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CRA	-		DO	4	4	110kV SF6 Cubicle Ordinary Service

110kV FEEDER - BELLACORICK SRAHNAKILLY

TO-22-BK-SKY-1-01

 Window: **Oct - Nov**

 Duration: **(6 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	6	N/A	Total Maintenance Outage Duration Requested
OPT	BK-		DO	1	4	110kV SF6 Cubicle Operational Test	
	Cable	-	901238134	DO	5	4	2021PM_ Investigation & repair of S-Phase
OPT	SKY		DO	1	4	110kV SF6 Cubicle Operational Test	

SECTIONALISING DISCONNECT - BOGGERAGH 110SA2

TO-22-BGH-110SA2-01

 Window: **Jun**

 Duration: **(3 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
OS	BGH	110-SA2		DO	2	4	110kV Sect / Dist Ordinary Service

110kV FEEDER - BOGGERAGH CLASHAVOON

TO-22-BGH-CLA-1-01

 Window: **Jun**

 Duration: **(3 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
			DO	3		Total Maintenance Outage Duration Requested	
CORRECT	CLA	-	901210822	DO	3	1	O1- HOTSPOT Boggeragh 110kv CT R&S Phase

GENERATOR TRANSFORMER - BOGGERAGH T121

TO-22-BGH-T121-01

 Window: **Jun**

 Duration: **(3 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
Opt	BGH		DO	1	4		110kV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - BOGGERAGH T132

TO-22-BGH-T132-01

 Window: **Jun**

 Duration: **(3 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	BGH		DO	1	4		110kV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - BOOLTIAGH T121

TO-22-BOL-T121-01

 Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
			DO	2	2		P2 Protection maintenance of 7SA611

GENERATOR TRANSFORMER - CARRIGADROHID T103

TO-22-CD-T103-01

 ISO week: **21mo - 22fr**

 Date: **23 May - 03 Jun**

 Duration: **12 Days (10 WD)**

 Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	10	N/A	Total Maintenance Outage Duration Requested
OS	CD	-	DO	4	4		110KV SF6 Cubicle Ordinary Service
CA_110	CD	-	DO	3	4		110KV CUBICLE CONDITION ASSESSMENT

110kV FEEDER - CARRIGDANGAN DUNMANWAY

TO-22-CGG-DMY-1-01

 Window: **May**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
AMCAB	-	cable	DO	4			Cable Insp. 110kV XLPE
OPT	CGG	-	DO	1	4		110kV GIS Cubicle Operational Test
OPT	DMY		DO	1	4		110kV MO Cubicle Operational Test

110KV FEEDER - CATHALEENS FALL CLIFF

TO-22-CF-CL-1-01

 Window: **May**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	6	N/A	Total Maintenance Outage Duration Requested
OS	CF~	-	DO	4	4	110kV SF6 Cubicle Ordinary Service	
CA_110	CF~	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT	
	CLF		DO	2	2	P2 Protection maintenance of 7SA511	

GENERATOR TRANSFORMER - CATHALEENS FALL T104

TO-22-CF-T104-01

 Window: **Sep**

 Duration: **(1 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPTSF61	CF~	-	901212524	DO	1	4	110KV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - CLIFF T101

TO-22-CL-T101-01

 ISO week: **14th - 14fr**

 Date: **07 Apr - 08 Apr**

 Duration: **2 Days (2 WD)**

 Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	2	N/A	Total Maintenance Outage Duration Requested
	CL~	-	901230085	DO	2	4	Repair corrosion issue on CTs

GENERATOR TRANSFORMER - CLIFF T102

TO-22-CL-T102-01

 Window: **May**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
			DO	2	1	P1 Protection maintenance of 7SJ511	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	CL~	-	901212652	DO	4	4	110KV SF6 Cubicle Ordinary Service
CA_110	CL~	-	901212213	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT
FOFAULT	CL~	-	901247276	DO		4	T102 – DL2 -LINE DISCONNECTS WILL NOT CL

SECTIONALISING DISCONNECT - CLOGHBOOLA 110SA1

TO-22-CBA-110SA1-01

 Window: **May - Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CBA	SA1	DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects	

SECTIONALISING DISCONNECT - CLOGHBOOLA 110SA2

TO-22-CBA-110SA2-01

 Window: **May - Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	110-SA2	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CBA	SA2		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

110kV FEEDER - CLOGHBOOLA TRIEN

TO-22-CBA-TRI-1-01

 Window: **May - Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
FO_CABLE	CBA	-	901155246	DO	2	3	Water ingress into link box at JB12 - ra
OPT	CBA			DO	1	4	110kV SF6 Cubicle Operational Test
FO_CABLE	CBA	-	901155245	DO	1	3	Clean CSE stand-off insulators in Cloghb
OPT	TRI			DO	1	4	110kV SF6 Cubicle Operational Test

110kV FEEDER - CLOGHER MULREAVY

TO-22-CLO-MRY-1-02

 Window: **Aug**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	2	3	P3 Protection maintenance of 7SA612, GRL100
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
AICX110S	CABLE	110		DO	2	3	Cable Insp. 110kV XLPE
OS	CLO	-		DO	4	4	110kV GIS Cubicle Ordinary Service
	MRY			DO	2	3	P3 Protection maintenance of 7SA612, GRL100, 7SJ804

110kV FEEDER - CLONKEEN COOMAGEARLAHY

TO-22-CKN-CGL-1-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AMCAB	Cable	-		DO	2	4	Cable Insp. 110kV XLPE
OPT	CGL			DO	1	4	110kV SF6 Cubicle Operational Test
	CKN	-		DO	3	4	OIL SAMPLING OF CT /R/S/T/ and INSPECT RUBBER BELLOWS
OPT	CKN			DO	1	4	110kV SF6 Cubicle Operational Test

110kV FEEDER - COOLNANOONAGH KILPADDOGE

TO-22-CNO-KPG-1-01

 ISO week: **15mo - 15th**

 Date: **11 Apr - 14 Apr**

 Duration: **4 Days (4 WD)**

Status:

Proposed

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	KPG	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
AMCAB	KPG	-		DO	2	4	Annual Insp. 110kV Feeder XLPE Cable

SECTIONALISING DISCONNECT - COOMAGEARLAHY 110SA1

TO-22-CGL-110SA1-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CGL	SA1		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

SECTIONALISING DISCONNECT - COOMAGEARLAHY 110SA2

TO-22-CGL-110SA2-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CGL	SA2		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

110kV FEEDER - COOMAGEARLAHY GLANLEE

TO-22-CGL-GAE-1-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AMCAB	CGL	-		DO	2	4	Cable Insp. 110kV XLPE
OPT	CGL			DO	1	4	110kV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - COOMAGEARLAHY T121

TO-22-CGL-T121-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	CGL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
CA_110	CGL	-		DO	3	4	110KV CUBICLE CONDITION ASSESSMENT

GENERATOR TRANSFORMER - COOMAGEARLAHY T122

TO-22-CGL-T122-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CGL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
	CGL	110		DO	3	4	OIL SAMPLING OF CT /R/S/T/ and INSPECT RUBBER BELLOWS

GENERATOR TRANSFORMER - COOMATAGGART T132

TO-22-COT-T132-02

 Window: **May**

 Duration: **(1 WD)**

 Status: **Planned**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	COT			DO	1	4	110kV SF6 Cubicle Operational Test

SECTIONALISING DISCONNECT - CORDAL 110SA1

TO-22-CDL-110SA1-02			Window: Sep	Duration: (5 WD)	Status: Planned		
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	CDL	110-SA1		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

SECTIONALISING DISCONNECT - CORDAL 110SA2

TO-22-CDL-110SA2-02			Window: Sep	Duration: (5 WD)	Status: Planned		
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	CDL	110-SA1-2		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

GENERATOR TRANSFORMER - CORDAL T132

TO-22-CDL-T132-02			Window: Sep	Duration: (5 WD)	Status: Planned		
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CDL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
AMCAB	CDL	-		DO	2	4	Cable Insp. 110kV XLPE

110kV FEEDER - CORDERRY GARVAGH

TO-22-CDY-GRV-1-02			Window: Jul	Duration: (5 WD)	Status: Planned		
N/A	-	-	N/A	DO	6	N/A	Total Maintenance Outage Duration Requested
	CDY	-	901246605	DO	5	4	CB Modification Required
OPT	CDY	-		DO	1		110kV SF6 Cubicle Operational Test
OS	GRV	-		DO	4	4	110kV GIS Cubicle Ordinary Service

220kV FEEDER - CORDUFF HUNTSTOWN

TO-22-CDU-HN-1-01			Status: Unscheduled				
WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	CDU	-		DO	5	4	220kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - CUSHALING T101

TO-22-CUS-T101-03			Window: Jul	Duration: (4 WD)	Status: Planned		
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	CUS	-		DO	4	4	110kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - CUSHALING T103/5

TO-22-CUS-T103/5-02

 Window: **Oct**

 Duration: **(1 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	CUS		DO	1	4	110kV SF6 Cubicle Operational Test	

GENERATOR TRANSFORMER - DERRYCARNEY T132

TO-22-DEY-T132-01

 Window: **Jul**

 Duration: **(1 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	DEY	110	DO	1	4	110kV AIS Cubicle Operational Test	

GENERATOR TRANSFORMER - DERRYIRON RHODE T1/T2

TO-22-DER-T1/T2-01

 ISO week: **15we - 15th**

 Date: **13 Apr - 14 Apr**

 Duration: **2 Days (2 WD)**

Status:

Scheduled

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
			DO	2	1	P1 Protection maintenance of 7SA513	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	DER		DO	1	4	110KV SF6 Cubicle Operational Test	

110kV FEEDER - DRUMKEEN MEENTYCAT

TO-22-DRM-MEE-1-02

 Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	2	P2 Protection maintenance of 7SA513

110kV FEEDER - ENNIS SLIEVECALLAN

TO-22-ENN-SLC-1-01

 Window: **Jun - Jul**

 Duration: **(15 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	15		Total Maintenance Outage Duration Requested
AICX4/2F	ENN	-	DO	15	2		Cable Insp. 110kV XLPE

220kV FEEDER - FINGLAS HUNTSTOWN

TO-22-FIN-HN-1-01

 ISO week: **9tu - 10mo**

 Date: **01 Mar - 07 Mar**

 Duration: **7 Days (5 WD)**

 Status: **Scheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
AMCAB	CABLE	-	DO	2	4		Cable Insp. 400 & 220kV Feeder XLPE
OS	FIN	-	DO	5	4		220kV SF6 Cubicle Ordinary Service
	FIN	-	DO	1	4		CHECK TORQUE OF MECHANISM DRIVE RODS
CORRECT	HUN	220-DL	901128554	DO	3	1	T Phase HotSpot on T Phase DL/DE disconnect HOTSPOT 1 MONTH DUE: 8-Jun-2021

GENERATOR TRANSFORMER - GARROW T122

TO-22-GRO-T122-01

 Window: **May - Jun**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	2	P2 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
CA_110	GRO	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT
AMCAB	GRO	-	DO	2	4	Cable Insp. 110kV XLPE
OPT	GRO	-	DO	1	4	110kV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - GLANAGOW T2001

TO-22-GGO-T2001-01

 Window: **Oct**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OS	GGO	-	DO	4	4	220kV GIS Cubicle Ordinary Service

GENERATOR TRANSFORMER - GLANLEE T121

TO-22-GAE-T121-01

 Window: **Jun**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	1	N/A	Total Maintenance Outage Duration Requested
OPT	GAE	-	DO	1	4	110kV SF6 Cubicle Operational Test

110KV FEEDER - GLENLARA KNOCKACUMMER

TO-22-GLE-KCR-1-01

 Window: **Aug**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	4	N/A	Total Maintenance Outage Duration Requested
OS	GLE	-	DO	4	4	110kV SF6 Cubicle Ordinary Service
OS	KCR	-	DO	4	4	110kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - GREAT ISLAND GIS T2004

TO-22-GI GIS-T2004-01

 Window: **Jul**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	1	P1 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OSGIS200	GI-	220	DO	4	4	220kV GIS Cubicle Ordinary Service
CA_220	GI-	220	DO	3	4	220KV CUBICLE CONDITION ASSESSMENT
OPTGIS2	GI-	220	901212273	1	4	220kV GIS Cubicle Operational Test

GENERATOR TRANSFORMER - HUNTSTOWN T2002

TO-22-HN-T2002-01

 Status: **Unscheduled**

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	9	N/A	Total Maintenance Outage Duration Requested
OSSF6220	HUN	-	901129991	DO	4	3	220kV SF6 Cubicle Ordinary Service
CA_110	HUN	-		DO	3	4	110KV CUBICLE CONDITION ASSESSMENT
AMCAB	HUN	-		DO	2	4	Cable Insp. 400 & 220kV Feeder XLPE
	HUN			DO	2	3	P3 Protection maintenance of 7SA612, GRL100

GENERATOR TRANSFORMER - HUNTSTOWN T2010/11

TO-22-HN-T2010/11-01

 ISO week: **9tu - 10mo**

 Date: **01 Mar - 07 Mar**

 Duration: **7 Days (5 WD)**

Status:

Scheduled

WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	HUN	-		DO	5	4	220kV SF6 Cubicle Ordinary Service
AIC4/2A	HUN	-	901005718	DO	2	3	Cable Insp. 400 & 220kV Feeder XLPE
	HUN	220		DO	1	4	CHECK TORQUE OF MECHANISM DRIVE RODS

110kV FEEDER - IKERRIN tee SHANNONBRIDGE

TO-22-IKE,T-SH-1-07

 Status: **Unscheduled**

FO_MISC	-	-	900989547	DO	1	2	2018HP-1[277]Bird Nestsremove
FO_MISC	-	-	901253942	DO	1	4	2021HP-1[236]Bird Nests

TO-22-IKE,T-SH-1-05

 Window: **Nov**

 Duration: **(15 WD)**

 Status: **Planned**

N/A	-	-	N/A	DO	15	N/A	Total Maintenance Outage Duration Requested
FOSTRHW	-	-	901167004	DO	2	4	{193}Poleset replacement @ 193 on the Sh
FO_MISC	-	-	901171426	DO	1	4	2020HP-1[191]Off Plumb (Straighten)
FOSTRHW	-	-	901172525	DO	1	4	2020HP-1[24]Check Structure Top Rot
FOSTRHW	-	-	901172526	DO	1	4	2020HP-1[38]Check Structure Top Rot
FOSTRHW	-	-	901172527	DO	1	4	2020HP-1[67]Check Structure Top Rot
FOSTRHW	-	-	901172528	DO	1	4	2020HP-1[180]Check Structure Top Rot
FOSTRHW	-	-	901172529	DO	1	4	2020HP-1[219]Check Structure Top Rot
	SH			DO	2	3	P3 Protection maintenance of 7SA612, REL521
OSSF6110	SH-	-	901212852	DO	4	4	110kV SF6 Cubicle Ordinary Service
CA_110	SH-	-	901212210	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT
CORRECT	SH-	-	901217879	DO	2	4	Ikerrin/Thurles "T" Phase CT Oli Leak

110kV FEEDER - IKERRIN tee THURLES

TO-22-IKE,T-THU-1-04

 ISO week: **19mo - 21fr**

 Date: **09 May - 27 May**

 Duration: **19 Days (15 WD)**

Status:

Proposed

N/A	-	-	N/A	DO	7	N/A	Total Maintenance Outage Duration Requested
FO_MISC	-	-	901126159	DO	1	4	2019LP-1[291]Off Plumb - Pole
OS	THU	-		DO	6	4	110kV MO Cubicle Ordinary Service
	THU			DO	2	2	P2 Protection maintenance of 7SA612, GRZ100

GENERATOR TRANSFORMER - INNISCARRA T101

TO-22-IA-T101-01

 Window: **May**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OS	IA~	-	DO	4	4	110KV SF6 Cubicle Ordinary Service
OPTSF61	IA~	901212533	DO	1	4	110KV SF6 Cubicle Operational Test

GENERATOR TRANSFORMER - IRISHTOWN T2001

TO-22-ISH-T2001-01

 Window: **Jul**

 Duration: **(3 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	3	N/A	Total Maintenance Outage Duration Requested	
AIC4/2A	ISH	220	901181269	DO	2	3	Cable Insp. 400 & 220kV Feeder XLPE
OPT	ISH		DO	1	4	220kV GIS Cubicle Operational Test	

GENERATOR TRANSFORMER - KILL HILL T131

TO-22-KHL-T131-01

 Window: **Jun**

 Duration: **(1 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	1	N/A	Total Maintenance Outage Duration Requested
OPT	KHL	110	DO	1	4	110kV SF6 Cubicle Operational Test

110kV FEEDER - KNOCKALOUGH KNOCKRANNY

TO-22-KLH-KNY-1-01

 ISO week: **14mo - 14fr**

 Date: **04 Apr - 08 Apr**

 Duration: **5 Days (5 WD)**

 Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OS	KLH	-	DO	4	4	110kV SF6 Cubicle Ordinary Service
AMCAB	KLH	-	DO	2	2	Cable Insp. 110kV XLPE
OS	KNY	-	DO	4	4	110kV SF6 Cubicle Ordinary Service

110kV FEEDER - KNOCKRANNY UGGOOL

TO-22-KNY-UGL-1-01

 Window: **Aug**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	4	N/A	Total Maintenance Outage Duration Requested
OS	KNY	-	DO	4	4	110kV GIS Cubicle Ordinary Service
OS	UGL	-	DO	4	4	110kV GIS Cubicle Ordinary Service

GENERATOR TRANSFORMER - LISHEEN T122

TO-22-LSN-T122-03

 Window: **May**

 Duration: **(2 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	1	P1 Protection maintenance of 7SA612
N/A	-	-	N/A	1	N/A	Total Maintenance Outage Duration Requested
OPT	LSN		DO	1	4	110kV SF6 Cubicle Operational Test

110kV FEEDER - LISHEEN THURLES

TO-22-LSN-THU-1-03

 Window: **May**

 Duration: **(2 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
OPT	LSN	-	DO	1		110kV SF6 Cubicle Operational Test
	THU		DO	2	1	P1 Protection maintenance of 7SA612
OPT	THU	-	DO	1		110kV MO Cubicle Operational Test

GENERATOR TRANSFORMER - LONG POINT T2002

TO-22-LPT-T2002-01

 Window: **Sep**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OS	LPT	-	DO	5	4	220kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - MONEYPPOINT GIS T121

TO-22-MP GIS-T121-01

 Window: **Jul**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	1	P1 Protection maintenance of 7SA612
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OSGIS110	MP~	TRAFO	DO	4	4	110kV GIS Cubicle Ordinary Service
AMCAB	MP~	-	DO	2	4	Cable Insp. 110kV XLPE

GENERATOR TRANSFORMER - MONEYPPOINT GIS T4003

TO-22-MP GIS-T4003-01

 Window: **Sep**

 Duration: **(4 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	5	N/A	Total Maintenance Outage Duration Requested
OS	MP~	400	DO	3	4	400kV GIS Cubicle Ordinary Service

GENERATOR TRANSFORMER - MOUNTLUCAS T121

TO-22-MLC-T121-01

 Window: **Jun**

 Duration: **(5 WD)**

 Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	2	P2 Protection maintenance of 7SA612
N/A	-	-	N/A	10	N/A	Total Maintenance Outage Duration Requested
OS	MLC	-	DO	4	4	110kV SF6 Cubicle Ordinary Service
CA_110	MLC	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT

GENERATOR TRANSFORMER - MULREAVY T131

TO-22-MRY-T131-02				Window: Aug	Duration: (5 WD)	Status: Planned	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OSSF6110	MRY	-	901129929	DO	4	3	110kV SF6 Cubicle Ordinary Service

SECTIONALISING DISCONNECT - POLLAPHUCA 110SA1

TO-22-PA-110SA1-03				Window: Jun	Duration: (10 WD)	Status: Planned	
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
OSSED110	POL	110-SA1	901212625	DO	3	3	110kV Sect / Dist Ordinary Service

SECTIONALISING DISCONNECT - POLLAPHUCA 110SA2

TO-22-PA-110SA2-03				Window: Jun	Duration: (10 WD)	Status: Planned	
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
OS	POL	110-SA2		DO	2	4	110kV Sect / Dist Ordinary Service

GENERATOR TRANSFORMER - POLLAPHUCA T101

TO-22-PA-T101-03				Window: Jun	Duration: (10 WD)	Status: Planned	
				DO	2	1	P1 Protection maintenance of 7SA511
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	POL	-		DO	1	4	110kV MO Cubicle Operational Test

GENERATOR TRANSFORMER - RATRUSSAN T121

TO-22-RRU-T121-02				Window: Jul	Duration: (5 WD)	Status: Planned	
				DO	2	2	P2 Protection maintenance of 7SV512
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	RRU	-		DO	4	4	110kV SF6 Cubicle Ordinary Service
	RRU	110		DO	3	4	OIL SAMPLING OF CT /R/S/T/ and INSPECT RUBBER BELLOWS

GENERATOR TRANSFORMER - RATRUSSAN T122

TO-22-RRU-T122-04				Window: May	Duration: (3 WD)	Status: Planned	
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
	RRU	110		DO	3	4	OIL SAMPLING OF CT /R/S/T/ and INSPECT RUBBER BELLOWS
OPT	RRU			DO	1	4	110kV SF6 Cubicle Operational Test

110kV FEEDER - REAMORE TRALEE

TO-22-REM-TRL-1-01

Window: **May**

Duration: **(2 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	2	N/A	Total Maintenance Outage Duration Requested
OPT	REM		DO	1	4	110kV SF6 Cubicle Operational Test	
OPT	TRL		DO	1	4	110kV SF6 Cubicle Operational Test	

GENERATOR TRANSFORMER - SEALROCK T103

TO-22-SK-T103-02

Window: **Nov**

Duration: **(3 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
CA_110	SK	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT

TO-22-SK-T103-01

Window: **Jul**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	10	N/A	Total Maintenance Outage Duration Requested
OS	SK	-	DO	4	4	110KV SF6 Cubicle Ordinary Service	

GENERATOR TRANSFORMER - SEALROCK T104

TO-22-SK-T104-01

Window: **Jun**

Duration: **(0 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	SK		DO	1	4	110KV SF6 Cubicle Operational Test	

GENERATOR TRANSFORMER - SHELLYBANKS T2014

TO-22-SHL-T2014-02

Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA513

GENERATOR TRANSFORMER - SHELLYBANKS T2015

TO-22-SHL-T2015-01

ISO week: **21mo - 21th**

Date: **23 May - 26 May**

Duration: **4 Days (4 WD)**

Status:

Proposed

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OSSEC220	SHL	220-DT	901130137	DO	3	3	220kV Sect / Dist Ordinary Service
AIC4/2A	SHL	-	901005629	DO	2	3	Cable Insp. 400 & 220kV Feeder XLPE

GENERATOR TRANSFORMER - SHELLYBANKS T2016

TO-22-SHL-T2016-01 ISO week: **22mo - 22we** Date: **30 May - 01 Jun** Duration: **3 Days (3 WD)** Status:

Proposed

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
OPTSEC2	SHL	220-DL	901042993	DO	3	2	220kV Sect / Dist Operational Test
AIC4/2A	SHL	220	901005630	DO	1	3	Cable Insp. 400 & 220kV Feeder XLPE

GENERATOR TRANSFORMER - SLIABH BAWN T132

TO-22-SLB-T132-02

Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
			DO	2	3	P3 Protection maintenance of 7SA612

SECTIONALISING DISCONNECT - SLIEVECALLAN 110SA1

TO-22-SLC-110SA1-01

Window: **Jun - Jul**

Duration: **(15 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	SLC	SA1		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

SECTIONALISING DISCONNECT - SLIEVECALLAN 110SA2

TO-22-SLC-110SA2-01

Window: **Jun - Jul**

Duration: **(15 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	SLC	SA2		DO	4	4	110kV Sect / Dist Ordinary Service including busbar disconnects

GENERATOR TRANSFORMER - SLIEVECALLAN T121

TO-22-SLC-T121-01

Window: **Jun - Jul**

Duration: **(15 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	6	N/A	Total Maintenance Outage Duration Requested
OS	SLC	110		DO	6	4	110kV MO Cubicle Ordinary Service

GENERATOR TRANSFORMER - SLIEVECALLAN T122

TO-22-SLC-T122-01

Window: **Jun - Jul**

Duration: **(15 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	6	N/A	Total Maintenance Outage Duration Requested
OS	SLC	110		DO	6	4	110kV MO Cubicle Ordinary Service

GENERATOR TRANSFORMER - SRAHNAKILLY T131

TO-22-SKY-T131-02

Window: **Oct - Nov**

Duration: **(6 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	SKY	110	DO	1	4	110kV SF6 Cubicle Operational Test	

GENERATOR TRANSFORMER - TARBERT T101

TO-22-TB-T101-01

ISO week: **14mo - 14fr**

Date: **04 Apr - 08 Apr**

Duration: **5 Days (5 WD)**

Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OS	TB~	-	DO	4		110KV SF6 Cubicle Ordinary Service	
CA_110	TB~	-	DO	3	4	110KV CUBICLE CONDITION ASSESSMENT	
AMCAB	TB~	-	DO	2	4	Annual Insp. 110kV Station OF Cable	

GENERATOR TRANSFORMER - TARBERT T102

TO-22-TB-T102-01

ISO week: **15mo - 15th**

Date: **11 Apr - 14 Apr**

Duration: **4 Days (4 WD)**

Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	TB~	-	DO	4	4	110KV SF6 Cubicle Ordinary Service	
AMCAB	TB~	-	DO	2	4	Annual Insp. 110kV Station OF Cable	

GENERATOR TRANSFORMER - TARBERT T2003

TO-22-TB-T2003-02

ISO week: **14tu - 15th**

Date: **05 Apr - 14 Apr**

Duration: **10 Days (8 WD)**

Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	8	N/A	Total Maintenance Outage Duration Requested
CA_220	TB~	-	DO	5	4	220KV CUBICLE CONDITION ASSESSMENT	
OS	TB~	-	DO	4		220kV MO Cubicle Ordinary Service	

GENERATOR TRANSFORMER - TAWNAGHMORE T1/T2

TO-22-TAW-T1/T2-01

Window: **Aug**

Duration: **(5 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	TAW	110	DO	4	4	110kV SF6 Cubicle Ordinary Service	

GENERATOR TRANSFORMER - TAWNAGHMORE T3

TO-22-TAW-T3-01

Window: **Aug**

Duration: **(4 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	TAW	110	DO	4	4	110kV SF6 Cubicle Ordinary Service	

110kV FEEDER - TULLABRACK tee BOOLTIAGH

TO-22-TBK,T-BOL-1-02

Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
	TBK		DO	2	2	P2 Protection maintenance of 7SA612, GRZ100

TO-22-TBK,T-BOL-1-01

Window: **Jul**

Duration: **(2 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OPT	BOL	-	DO	1	4		110kV SF6 Cubicle Operational Test

110kV FEEDER - TULLABRACK tee MONEYPOINT GIS

TO-22-TBK,T-MP GIS-1-01

Status: **Unscheduled**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	5	N/A	Total Maintenance Outage Duration Requested
OSGIS110	MP~	-	DO	4	4		110kV GIS Cubicle Ordinary Service

TO-22-TBK,T-MP GIS-1-02

Window: **Jul**

Duration: **(2 WD)**

Status: **Planned**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
FO_MISC	-	-	901168382	DO	2	4	2020LP-1[99]Off Plumb (4 Heads off)
AICX110F	MP~	-	DO	2	4		Annual Insp. 110kV Feeder XLPE Cable

GENERATOR TRANSFORMER - TURLOUGH HILL T2001/2

TO-22-TH-T2001/2-01 ISO week: **21th - 25mo** Date: **26 May - 20 Jun** Duration: **26 Days (17 WD)** Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	8	N/A	Total Maintenance Outage Duration Requested
OS	TH~	-	DO	5	4		220kV MO Cubicle Ordinary Service
CA_220	TH~	-	DO	3	4		220KV CUBICLE CONDITION ASSESSMENT
AICO4/2S	TH~	-	901212197	DO	2	4	Annual Insp. 400 & 220 Station OF Cable

GENERATOR TRANSFORMER - TURLOUGH HILL T2003/4

TO-22-TH-T2003/4-01 ISO week: **18we - 21th** Date: **04 May - 26 May** Duration: **23 Days (17 WD)** Status: **Proposed**

WORK	LOCATION	WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS	
N/A	-	-	N/A	DO	8	N/A	Total Maintenance Outage Duration Requested
OSMO110	TH~	220	901129829	DO	5	3	110kV MO Cubicle Ordinary Service
CA_220	TH~	-	DO	3	4		220KV CUBICLE CONDITION ASSESSMENT
AIC4/2A	TH~	-	901181273	DO	2	4	Annual Insp. 400 & 220 Station OF Cable

GENERATOR TRANSFORMER - TYNAGH T2001/2

TO-22-TY-T2001/2-02			Window: Aug	Duration: (3 WD)	Status: Planned		
N/A	-	-	N/A	DO	3	N/A	Total Maintenance Outage Duration Requested
OPT	TYN	-		DO	3	4	220kV SF6 Cubicle Operational Test
CORRECT	TYN	220-DL	901135020	DO	3	3	O1-Replace T2001/2 220kv Contacts on DL

COUPLER/SECTIONALISING CB - UGGOOL 110SA1-2CB

TO-22-UGL-110SA1-2CB-01			Window: Aug	Duration: (4 WD)	Status: Planned		
WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
OS	UGL	110-SA1-2		DO	4	4	110kV GIS Cubicle Ordinary Service
OS	UGL	SA2		DO	2	4	110kV Sect / Dist Ordinary Service
OS	UGL	SA1		DO	2	4	110kV Sect / Dist Ordinary Service

GENERATOR TRANSFORMER - UGGOOL T131

TO-22-UGL-T131-01			Window: Aug	Duration: (5 WD)	Status: Planned		
WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AICX110F	UG	110		DO	2	1	Annual Insp. 110kV Feeder XLPE Cable
OS	UGL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - UGGOOL T132

TO-22-UGL-T132-01			Window: Aug	Duration: (5 WD)	Status: Planned		
WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AICX110F	UG	110		DO	2	1	Annual Insp. 110kV Feeder XLPE Cable
OS	UGL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - UGGOOL T134

TO-22-UGL-T134-01			Window: Aug	Duration: (4 WD)	Status: Planned		
WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	4	N/A	Total Maintenance Outage Duration Requested
AICX110F	UG	110		DO	2	1	Annual Insp. 110kV Feeder XLPE Cable
OS	UGL	-		DO	4	4	110kV SF6 Cubicle Ordinary Service

GENERATOR TRANSFORMER - WOODHOUSE T122

TO-22-WOH-T122-01			ISO week: 18tu	Date: 03 May	Duration: 1 Day (1 WD)	Status: Proposed	
WORK	LOCATION		WORK ID	STATUS	DAYS	PRIORITY	DESCRIPTION/COMMENTS
N/A	-	-	N/A	DO	1	N/A	Total Maintenance Outage Duration Requested
OPT	WOO			DO	1	4	110kV SF6 Cubicle Operational Test