



Enhanced Performance Monitoring System

Update to Joint Grid Code Review Panel

Ross Fallon

31/01/2018



Enhanced Performance Monitoring System

Deliver a comprehensive tool to enable the TSO to monitor performance of all Users and the timely provision of data to those Users



EPMS Phase 1


Automation of existing performance monitoring activities for wind farm monthly reports and producing operating reserve reports




Future EPMS

Comprehensive performance monitoring of all DS3 system services and Grid Code

EPMS Timeline




 EPMS Activities

 DS3 Activities

Terms of Reference

- Introduce the application to a subset of industry to gain experience before 'go-live'
- Seek recommendations on the following aspects:
 - Any tolerances to be applied compliance with required performance.
 - Priority levels (from P1 to P5) that should be applied to any non performance issues identified.
 - Timelines for resolution of issues for each
- Provide feedback on EPMS Phase 1 to enable future development of the system.

What's Monitored?



Performance Monitoring Concept

- Examine units performance for an event (event can be a day or a discrete time period);
- Average the performance over the last X no. of events;
- Determine the unit's deviation, if any, from the expected performance;
- If the deviation is not within an acceptable tolerance it is deemed a non-performance issue;
- Determine a priority (1 to 5) based on the severity of the deviation and indicate timeline for resolution.

Inputs and Outputs

SCADA

EDIL

Meter

PMU

Grid
Code

Event
Recorders

VTOD

Contracts

Derogations



Detailed Reports

Summary Reports

Raw Data

User Reports



Frequency Response - Detailed Summary

Company:	Generation Co.
Unit:	XYZ
Date Report Run:	24/01/2018 08:14:00
Event Date & Time:	10/01/2018 12:03:23.000
Fuel:	PRIMARY(GAS)

Frequency Response

	POR	SOR	TOR1
Expected Response (MW)	10.073	11.175	-0.00
Achieved Response (MW)	11.41	31.859	22.293

Pre-Event Analysis

Pre-Event measured at (sec):	-60 to -30	Frequency Movement -60 to -30 :	0.04	Hz
Pre-Event Frequency (Hz):	50.008	Unit Movement -60 to -30 :	5.69	MW
Pre-Event Output (MW):	221.00			
Unit Ramping:	No			
Frequency Response:	ON			
Declared Availability (MW):	280.00			

Generator Capabilities

Registered Capacity (MW):	300.00	Governor Alpha:	0
Droop Capacity (MW):	105.00	Governor Beta:	0
Governor Droop (%):	4.00	90% Droop:	4.00
Inertia Constant H (MWs/MVA):	4.25	Frequency Rated (Hz):	50.00
Machine Rating (MVA):	320.00	Inertia Calculation Tolerance (MW):	2.954

Event Analysis

T0 measured at (Hz):	49.77	MW Data Moving Average Used:	Raw
Event Start Time:	12:03:23.000		
Event frequency nadir (Hz):	49.41	Measurement PMU:	Primary
RoCoF (Hz/sec):		RoCoF measurement time (sec):	5

POR

POR nadir occurred at (sec):	5
POR Nadir (Hz):	49.52

	Expected (MW)	Achieved (MW)
Delivered at nadir:	10.073	11.406
Delivered at nadir ± 0.5 sec:	10.073	11.406
Sustained Response:	NA	NA
Average Energy Delivered:	4.133	20.937

Shortfall (MW)
NA





Frequency Response - Overall Summary

Company:	Generation Co.
Unit:	XYZ
Date Report Run:	24/01/2018 08:14:00
No. Events Performance Assessed Over:	3
Compliance Duration:	03/01/2018 - 10/01/2018

[View Performance Issue Events](#)

FREQUENCY RESPONSE

Current Performance

	POR	SOR	TOR1
Required Performance (%)	100	100	100
Average Achieved/Expected (last 3 events) (%)	82.48	100.00	100.00
Priority	Priority 4	Compliant	Compliant
Status	Open	NA	NA
Date Raised	03/01/2018	NA	NA
Date Priority Updated	10/01/2018	NA	NA
Resolution Required By	03/05/2018	NA	NA

Date	Unit	Event Nadir (Hz)	POR Nadir (Hz)	RoCoF (Hz/Sec)	Nadir at (sec)	Declared Availability (MW)	Pre-Event Output (MW)	Expected POR (MW)	Achieved POR (MW)	Expected SOR (MW)	Achieved SOR (MW)	Expected TOR1 (MW)	Achieved TOR1 (MW)
03/01/2018 14:04	XYZ	49.76	49.86	0.21	5.00	470.00	287.56	14	12.14	15.17	16.907	NA	8.478
08/01/2018 07:22	XYZ	49.79	49.80	0.34	5.00	473.00	251.63	14	10.13	6.85	6.823	NA	8.423
10/01/2018 12:03	XYZ	49.41	49.52	0.40	5.00	471.00	248.96	13.8	11.406	11.175	12.859	NA	22.293 D

	Achieved < Expected (with tolerance)
	Achieved ≥ Expected (with tolerance)
	Not expected to provide reserve
NA	Frequency recovered during timeframe
D	Dispatched during period

Raw Data Reports



Low FR Conventional Data Input

User Input	
Parameter	Value
Unit Name	XYZ
Company	Generation Co
Date	10/01/2018 12:03:23.000

Data Input	
Parameter	Value
SOR R1	25.40
SOR R2	25.40
SOR RMX	30.00
SOR Timeframe End	89.99
SOR Timeframe Start	15.00
SOR β	0
SOR $\Delta 1$	0
SOR $\Delta 2$	35.00
SOR $\Delta 3$	35.00
TOR1 GRMN	160.00
TOR1 R0	0
TOR1 R1	25.00
TOR1 R2	25.00
TOR1 RMX	28.00
TOR1 Timeframe End	299.99
TOR1 Timeframe Start	90.00
TOR1 β	0
TOR1 $\Delta 1$	0



Low FR Conventional Raw data							
Time	Event Time (Seconds)	Frequency (Hz)	Active Power Output (MW)	Active Power Setpoint (MW)	Active Power Setpoint - Accept (MW)	Declared Availability (MW)	Declared Reserve (MW)
17/01/2018 12:02:23.00	-60.00	50.01	24.58	242.00	242.00	300.00	20.00
17/01/2018 12:02:24.00	-59.00	50.01	242.00	242.00	242.00	300.00	20.00
17/01/2018 12:02:25.00	-58.00	50.00	242.80	242.00	242.00	300.00	20.00
17/01/2018 12:02:26.00	-57.00	50.00	242.80	242.00	242.00	300.00	20.00
17/01/2018 12:02:27.00	-56.00	50.00	242.80	242.00	242.00	300.00	20.00
17/01/2018 12:02:28.00	-55.00	50.00	242.00	242.00	242.00	300.00	20.00
17/01/2018 12:02:29.00	-54.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:30.00	-53.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:31.00	-52.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:32.00	-51.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:33.00	-50.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:34.00	-49.00	49.99	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:35.00	-48.00	50.00	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:36.00	-47.00	50.00	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:37.00	-46.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:38.00	-45.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:39.00	-44.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:40.00	-43.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:41.00	-42.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:42.00	-41.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:43.00	-40.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:44.00	-39.00	50.01	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:45.00	-38.00	50.02	242.31	242.00	242.00	300.00	20.00
17/01/2018 12:02:46.00	-37.00	50.02	242.31	242.00	242.00	300.00	20.00



Industry Group Summary

- Familiarisation with the application
- Ideally group will consist at least one from the various technology types: e.g. CCGT, hydro, wind, DSU etc.
- Nomination by February 16th 2018
- Industry Group to commence in March 2018 for 3-6 months

**Please submit expressions of interest by
Friday 16th February 2018**

GridCode@eirgrid.com

