

# MODIFICATION RECOMMENDATION FORM



*RECOMMENDATION TO CER BY EIRGRID OF MODIFICATION TO GRID  
CODE.*

<b>ABSTRACT / TITLE OF MODIFICATION</b>	<b>HOUSEKEEPING OF GRID CODE CLAUSE OC10.4.5.2</b>
<b>MODIFICATION NUMBER</b>	MPID 244
<b>RECOMMENDED AT GCRP MEETING NUMBER</b>	GCRP #37
<b>LIST OF GRID CODE SECTION(S) AFFECTED BY PROPOSED MODIFICATION:</b>	OC10.4.5.2
<b>CURRENT GRID CODE VERSION :</b>	5

**MODIFICATION DESCRIPTION Overview****THE REASON FOR THE  
RECOMMENDED MODIFICATION**

EirGrid propose the re-numbering of the subsections to the clause OC10.5.4.2. The subsections are incorrectly numbered in the current version of the Grid Code (version 5). No text changes are proposed.

We recommend the re-numbering of the subsections as highlighted in blue below.

OC10.4.5.2 Compliance of **Demand Side Units** with **Dispatch Instructions**

The following validation will be performed in real time:

- (i) A **Demand Side Unit** shall be deemed compliant if the **SCADA** signal confirms that the **Demand Side Unit MW Response** is within 5% of the **Dispatch Instruction**.

The following validation will be performed post event:

- (ii) A **Demand Side Unit** shall be deemed to be compliant with the **Dispatch Instruction** if the difference between the **Demand Side Unit Energy Profile** and the metered **Demand** plus the **Demand Side Unit MW Response** is within 5% of the **Demand Side Unit Energy Profile**.
- (iii) For **Demand Side Units** which are not **Dispatched** but have been declared **Available** in an **Availability Notice**, the **Demand Side Unit** shall be deemed to be compliant with its declared **Demand Side Unit Energy Profile** if the difference between the **Demand Side Unit Energy Profile** and the metered **Demand** is within 5% of the **Demand Side Unit Energy Profile**.

<b>History of Progression through GCRPs, Working Group and/or Consultation</b>	EirGrid presented the modification proposal MPID 244 to the Grid Code Review Panel members at a meeting held in the Clarion IFSC Hotel in Dublin on the 4 <sup>th</sup> December 2013. No objections were raised by the panel members and the modification was recommended for approval.
<b>Summary Note of any Objections to the Recommended change from GCRP Members or Consultation Responses</b>	No objections were raised.
<b>Outcome of any GCRP Meeting Actions Relating to the Recommended Modification</b>	No actions were raised.
<b>Implication of not implementing the Modification</b>	The subsections of clause OC10.5.4.2 would remain incorrectly numbered in subsequent versions of the Grid Code.