

MODIFICATION RECOMMENDATION

FORMHOUSEKEEPING MOD - WFPS Active Power Control Mode (MPID 251)



RECOMMENDATION TO CER BY EIRGRID OF MODIFICATION TO GRID CODE.

ABSTRACT / TITLE OF MODIFICATION	HOUSEKEEPING MOD - WFPS Active Power Control Mode (MPID 251)
MODIFICATION NUMBER	MPID 251
RECOMMENDED AT GCRP MEETING NUMBER	39
LIST OF GRID CODE SECTION(S) AFFECTED BY PROPOSED MODIFICATION:	WFPS1.5.2.1 and WFPS1.5.3.3
CURRENT GRID CODE VERSION :	5
MODIFICATION DESCRIPTION Overview THE REASON FOR THE RECOMMENDED MODIFICATION	<p>This modification aims to rectify an incorrect term in WFPS1.5.2.1 and WFPS1.5.3.3. In these clauses the term Active Power Dispatch Mode is referred to. This term is not a defined term and should be replaced by the defined term Active Power Control Mode.</p>
History of Progression through GCRPs, Working Group and/or Consultation	<p>EirGrid presented the modification proposal MPID 251 to the Grid Code Review Panel members at a meeting held at The Spencer Hotel in Dublin on the 11th June 2014. No objections were raised by the panel members and the modification was recommended for approval.</p>
Summary Note of any Objections to the Recommended change from GCRP Members or Consultation Responses	<p>No objections were raised.</p>

<p>Outcome of any GCRP Meeting Actions Relating to the Recommended Modification</p>	<p>No objections were raised.</p>
<p>Implication of not implementing the Modification</p>	<p>The incorrect term in clause WFPS1.5.2.1 and WFPS1.5.3.3 would remain in subsequent versions of the Grid Code.</p>

RED-LINE VERSION

WFPS1.5.2.1 Active Power Control

The **Wind Farm Control System** shall be capable of operating each **WTG** at a reduced level if the **Controllable WFPS's Active Power** output has been restricted by the **TSO**. In this **Active Power Control Dispatch Mode**, the **Wind Farm Control System** shall be capable of receiving an on-line **Active Power Control Set-point** sent by the **TSO** and shall commence implementation of the set-point within 10 seconds of receipt of the signal from the **TSO**. The rate of change of output to achieve the **Active Power Control Set-point** should be the **Active Power Control Set-Point Ramp Rate** setting of the **Wind Farm Control System**, as advised by the **TSO**, as per WFPS1.5.4. The **TSO** acknowledges that if the **Active Power** output of the **Controllable WFPS** is initially less than the **Design Minimum Operating Level**, and if the **Controllable WFPS** is expected to increase its **Active Power** output, then it may not be able to achieve the specified ramp rate at first, due to **WTGs** going through a start-up sequence. In such a case, **WTGs** shall start up as quickly as the technology allows, and in any case, not longer than three minutes from the time the **Active Power Control Set-point** was received.

WFPS1.5.3.3 When acting to control **Transmission System Frequency**, the **Controllable WFPS** shall provide at least 60% of its expected additional **Active Power** response within 5 seconds, and 100% of its expected additional **Active Power** response within 15 seconds of the start of the **Transmission System Frequency** excursion outside the range FB-FC, or in the case of a **Controllable WFPS** in **Active Power Control Dispatch Mode**, when the **Transmission System Frequency** goes outside the deadband set out in WFPS1.5.3.2.

GREEN-LINE VERSION

WFPS1.5.2.1 Active Power Control

The **Wind Farm Control System** shall be capable of operating each **WTG** at a reduced level if the **Controllable WFPS's Active Power** output has been restricted by the **TSO**. In this **Active Power Control Mode**, the **Wind Farm Control System** shall be capable of receiving an on-line **Active Power Control Set-point** sent by the **TSO** and shall commence implementation of the set-point within 10 seconds of receipt of the signal

from the **TSO**. The rate of change of output to achieve the **Active Power Control Set-point** should be the **Active Power Control Set-Point Ramp Rate** setting of the **Wind Farm Control System**, as advised by the TSO, as per WFPS1.5.4. The **TSO** acknowledges that if the **Active Power** output of the **Controllable WFPS** is initially less than the **Design Minimum Operating Level**, and if the **Controllable WFPS** is expected to increase its **Active Power** output, then it may not be able to achieve the specified ramp rate at first, due to **WTGs** going through a start-up sequence. In such a case, **WTGs** shall start up as quickly as the technology allows, and in any case, not longer than three minutes from the time the **Active Power Control Set-point** was received.

WFPS1.5.3.3 When acting to control **Transmission System Frequency**, the **Controllable WFPS** shall provide at least 60% of its expected additional **Active Power** response within 5 seconds, and 100% of its expected additional **Active Power** response within 15 seconds of the start of the **Transmission System Frequency** excursion outside the range FB-FC, or in the case of a **Controllable WFPS** in **Active Power Control Mode**, when the **Transmission System Frequency** goes outside the deadband set out in WFPS1.5.3.2.