



An Coimisiún
um Rialáil Fóntais
Commission for
Regulation of Utilities



The Grain House
The Exchange
Belgard Square North
Tallaght, Dublin 24
D24 PXW0

T +353 1 4000 800
F +353 1 4000 850
E info@cru.ie
www.cru.ie

Miriam Ryan
EirGrid Plc
The Oval
160 Shelbourne Road
Ballsbridge
Dublin 4
Ireland

9 November 2020

Our Ref: D/20/22163

Re: Approval of the Grid Code Modification Recommendation MPID 279

Dear Miriam,

I refer to your correspondence to CRU of 10 August 2020 seeking approval of Grid Code modification MPID 279, as recommended at a Grid Code Review Panel meeting on 3 July 2020.

The CRU is satisfied that EirGrid has recommended this modification for approval by the CRU in accordance with the relevant provisions set out in the Grid Code for the handling of revisions and that the views of stakeholders have been adequately considered and addressed.

Having considered the recommendation and its supporting documentation the CRU approves the proposed modification. The CRU is satisfied that the maximum voltage withstand capability shown in the graphs under clause PPM1.6.3.4. is inconsistent with the limits set out in clause CC.8.3.2., and considers that the graphs should be updated.

The CRU now directs EirGrid to revise the Grid Code to take account of the approved modification. The Grid Code shall be deemed to be amended accordingly from the date of this letter.

Yours sincerely,

Sent by email and accordingly bears no signature

Robert O'Rourke
Manager of Electricity Networks

cc. Paul Harrington, Chair of DCRP,
John Ging, Chair of GCRP