

**Other System Charges (OSC) Trip Report
2021/2022**

| Date | Unit | MW Lost | Pre-incident [Hz] | Frequency Nadir [Hz] | Trip Type |
|------------------|---------------------------------------|----------------|--------------------------|-----------------------------|---------------------|
| 02/10/2021 21:30 | ESB Power Generation unit MP2 | 240.58 | | 49.88 | Fast Wind-down Trip |
| 11/10/2021 11:08 | Ballylumford CCGT unit 32 | 100.38 | | 49.865 | Direct Trip |
| 16/10/2021 12:35 | Tynagh Energy Limited unit TYC | 207.07 | | 49.81 | Direct Trip |
| 17/10/2021 18:36 | Tynagh Energy Limited unit TYC | 189.23 | | 50.05 | Direct Trip |
| 21/10/2021 14:03 | EP Kilroot Power Limited unit K2 | 221.925 | | 49.773 | Direct Trip |
| 25/10/2021 10:27 | SSE Generation Ireland Ltd unit TB3 | 235.3 | | 49.75 | Direct Trip |
| 28/10/2021 14:28 | ESB Power Generation unit AD2 | 167.76 | | 49.8 | Direct Trip |
| 28/10/2021 20:47 | ESB Power Generation unit AD2 | 137.44 | | 49.81 | Direct Trip |
| 01/11/2021 08:43 | ESB Power Generation unit AD2 | 423.72 | | 49.77 | Fast Wind-down Trip |
| 10/11/2021 11:27 | Power NI Energy Limited B32 | 211.01 | | 49.79 | Direct Trip |
| 10/11/2021 18:11 | Tynagh Energy Limited unit TYC | 343.74 | | 49.74 | Direct Trip |
| 14/11/2021 22:22 | Synergen Power Ltd unit DB1 | 131.26 | | 49.89 | Fast Wind-down Trip |
| 18/11/2021 13:44 | Bord Gais Energy Ltd unit WG1 | 377.4 | | 49.69 | Direct Trip |
| 22/11/2021 12:51 | Bord Gais Energy Ltd unit WG1 | 136.51 | | 49.82 | Fast Wind-down Trip |
| 22/11/2021 21:32 | Bord Gais Energy Ltd unit WG1 | 442.16 | | 49.64 | Direct Trip |
| 22/11/2021 21:32 | ESB Power Generation unit AD2 | 101.83 | | 49.64 | Direct Trip |
| 22/11/2021 21:32 | Synergen Power Ltd unit DB1 | 400.25 | | 49.64 | Direct Trip |
| 24/11/2021 19:52 | Coolkeeragh ESB Limited C30 | 255.71 | | 49.787 | Direct Trip |
| 29/11/2021 22:02 | EP Kilroot Power Limited K1 | 123.14 | | 49.763 | Direct Trip |
| 02/12/2021 13:37 | SSE Generation Ireland Ltd unit TB3 | 155.22 | | 49.88 | Direct Trip |
| 10/12/2021 17:49 | ESB Power Generation unit AD2 | 440.14 | | 49.74 | Fast Wind-down Trip |
| 16/12/2021 21:28 | SSE Generation Ireland Ltd unit TB3 | 233.02 | | 49.85 | Fast Wind-down Trip |
| 20/12/2021 11:47 | ESB Power Generation unit MP3 | 291.12 | | 49.79 | Fast Wind-down Trip |
| 24/12/2021 09:48 | SSE Generation Ireland Ltd unit TB3 | 214.64 | | 49.85 | Fast Wind-down Trip |
| 28/12/2021 10:27 | Tynagh Energy Limited unit TYC | 124.15 | | 49.85 | Direct Trip |
| 29/12/2021 15:33 | Edenderry Power unit ED1 | 107.23 | | 49.85 | Slow Wind-down trip |
| 31/12/2021 20:34 | Bord Gais Energy Ltd unit WG1 | 173.75 | | 49.78 | Direct Trip |
| 02/01/2022 01:19 | Bord Gais Energy Ltd unit WG1 | 172.75 | | 49.84 | Direct Trip |
| 04/01/2022 12:06 | ESB Power Generation unit AD2 | 143.65 | | 49.86 | Fast Wind-down Trip |
| 05/01/2022 09:07 | Tynagh Energy Limited unit TYC | 133.89 | | 49.84 | Direct Trip |
| 10/01/2022 12:10 | Coolkeeragh ESB Limited unit C30 | 398.525 | | 49.85 | Direct Trip |
| 04/02/2022 20:15 | ESB Power Generation unit MP1 | 262.99 | | 49.87 | Fast Wind-down Trip |
| 20/02/2022 13:02 | ESB Power Generation unit MP1 | 312.85 | | 49.86 | Fast Wind-down Trip |
| 22/02/2022 18:14 | Edenderry Power unit ED1 | 103.53 | | 49.89 | Fast Wind-down Trip |
| 25/02/2022 16:49 | Bord Gais Energy Ltd unit WG1 | 191.87 | | 49.81 | Direct Trip |
| 23/03/2022 07:34 | Coolkeeragh ESB Limited unit C30 | 411.93 | | 49.71 | Direct Trip |
| 09/04/2022 04:55 | Energia Power Generation Ltd unit HN2 | 326.41 | | 49.74 | Direct Trip |
| 09/04/2022 09:10 | Energia Power Generation Ltd unit HN2 | 155.84 | | 49.89 | Direct Trip |
| 10/05/2022 15:45 | Coolkeeragh ESB Limited unit C30 | 220.936 | | 49.842 | Direct Trip |
| 13/05/2022 11:58 | ESB Power Generation unit MP3 | 121.88 | | 49.91 | Fast Wind-down Trip |
| 25/05/2022 12:11 | Coolkeeragh ESB Limited unit C30 | 113.794 | | 49.84 | Direct Trip |
| 30/05/2022 23:35 | ESB Power Generation unit MP1 | 124.4 | | 49.89 | Slow Wind-down trip |